

BUILDING SAFETY CERTIFICATE

L.NO.....150/AE-Dcamp/26

Date: 23/01/26

It is certified that the existing building **Shri Guru Narayan Khatri Saraswati Shishu Mandir** (name of the building or premises) at **16/114 Civil Lines Kanpur Nagar (U.P)** (address) is having block(s)/Floor(s) as per detail below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	G+2	-	-	-	-	-

The building is owned/occupied by **Shri Guru Narayan Khatri Saraswati Shishu Mandir, 16/114 Civil Lines Kanpur Nagar** (name of the institution) have complied with the Building safely requirements in accordance with National Building code Rules, and verified by the officers concerned of **P.W.D (U.P)** (Name of Department/ Govt.) on 23.01.2026 (date of inspection) in the presence of **Shri Surendra Kakkar** (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 23.01.2026 For a period of **One** years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Ramp and Ralling Providing for Physical handicap student.
2. Stair-case width is 1.5 meter riser 15 cm and tread 30 cm.
3. This Certificate is valid for the construction which is in existence on inspection date.

Issued on 23.01.2026 at by **16/114 Civil Lines Kanpur Nagar (U.P)**

*strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

सहायक अभियन्ता
निर्माण खण्ड भवन, लो0नि0वि0
कानपुर नगर
JE